




Shapoorji Pallonji Mideast (L.L.C)
Sulaiman Al Habib Medical Center
SCANNED

 د. سليمان الحبيب DR SULAIMAN AL HABIB مؤسسة الدكتور سليمان الحبيب	 Arif & Bintook CONSULTING ARCHITECTS & ENGINEERS	 شاپورजी पालोजी मीडियास्ट Shapoorji Pallonji Mideast (L.L.C.)	MATERIAL APPROVAL REQUEST
--	--	--	----------------------------------

CONTRACT NO.	1485/69	MAR NO.	1485/SPML/CIVIL/ST/MAR-009
CONTRACT TITLE:	PROPOSED HOSPITAL DEVELOPMENT BUILDING (3B+G+6+ROOF) IN PLOT NO. C/P57 IN DUBAI HEALTH CARE CITY FZ LLC.	REVISION NO.:	1
CLIENT	DR. SULAIMAN AL HABIB MEDICAL CENTER FZ LLC	DATE	2-Jul-13
CONSULTANT	ARIF & BINTOAK CONSULTING ARCHITECTS & ENGINEERS	DISCIPLINE	Structural
CONTRACTOR:	SHAPOORJI PALLONJI MIDEAST (LLC)		

PRODUCT NAME TURBO SEAL - Poly Rubber Gel
MANUFACTURER M/S ALL ASPECTS - *NIP System*
TO : Eng. *Mohamad Khalaf* MOHAMMED KHAULAD - Resident Engineer
FROM : Eng. Santosh Babu J. - Sr. Project Manager


 Signature: _____
 Date: _____


DESCRIPTION:

Material Approval Request for Substructure Water Proofing *System* -
TURBO-SEAL COMPLETE for Vertical & Horizontal.

LEAD SECTOR CONSULTANT'S COMMENTS :

- water Proofing *System* & Guarantee to be submitted in accordance with the project specifications
 - Implementation to be strictly followed as per manufacturer's recommendation.
 - Submit IR prior to commencing the work.
- [Signature]*
21/7/13

EMPLOYER / PM COMMENTS :


 RECEIVED
 02 JUL 2013
 Shapoorji Pallonji Mideast (L.L.C)
 Sulaiman Al Habib Medical Center

SUBMITTAL STATUS

APPROVED NO COMMENTS <input type="checkbox"/> APPROVED AS NOTED <input checked="" type="checkbox"/> NOT APPROVED - RESUBMIT <input type="checkbox"/>	FOR RECORD ONLY <input type="checkbox"/> EMPLOYER APPROVAL REQUIRED <input type="checkbox"/>
--	---


LEAD SECTOR CONSULTANT'S SIGNATURE


For and on behalf of
Arif & Bintook

 Date: 21/7/13


 RECEIVED
 02 JUL 2013
 1485

MATERIAL APPROVAL REQUEST

	
CONTRACT NO. 1485/69	MAR NO. 1485/SPML/CIVIL/ST/MAR-009
CONTRACT TITLE: PROPOSED HOSPITAL DEVELOPMENT BUILDING (3B+G+6+ROOF) IN PLOT NO. C/P57 IN DUBAI HEALTH CARE CITY FZ LLC.	REVISION NO.: 0
CLIENT DR. SULAIMAN AL HABIB MEDICAL CENTER FZ LLC	DATE 22-Jun-13
CONSULTANT ARIF & BINTOAK CONSULTING ARCHITECTS & ENGINEERS	DISCIPLINE Structural
CONTRACTOR: SHAPOORJI PALLONJI MIDEAST (LLC)	
PRODUCT NAME TURBO SEAL - Poly - Rubber Gel.	SAMPLE PROVIDED <input checked="" type="checkbox"/>
MANUFACTURER M/S ALL ASPECTS	SUPPLIER

TO : Eng. Jeetendra MS - Resident Engineer	FROM : Eng. Santosh Babu J. - Sr. Project Manager														
<table border="1" style="margin: auto;"> <tr><th colspan="2">ARIF & BINTOAK</th></tr> <tr><td colspan="2">PRV Project No.1485</td></tr> <tr><td><input type="checkbox"/></td><td>Approved</td></tr> <tr><td><input type="checkbox"/></td><td>Approved as Noted</td></tr> <tr><td><input checked="" type="checkbox"/></td><td>Revise & Resubmit</td></tr> <tr><td><input type="checkbox"/></td><td>Rejected</td></tr> <tr><td><input type="checkbox"/></td><td>Other</td></tr> </table>	ARIF & BINTOAK		PRV Project No.1485		<input type="checkbox"/>	Approved	<input type="checkbox"/>	Approved as Noted	<input checked="" type="checkbox"/>	Revise & Resubmit	<input type="checkbox"/>	Rejected	<input type="checkbox"/>	Other	 <i>Santosh Babu J.</i> Date: 22/6/2013
ARIF & BINTOAK															
PRV Project No.1485															
<input type="checkbox"/>	Approved														
<input type="checkbox"/>	Approved as Noted														
<input checked="" type="checkbox"/>	Revise & Resubmit														
<input type="checkbox"/>	Rejected														
<input type="checkbox"/>	Other														
SIGN	DATE														

DESCRIPTION: Material Approval Request for Substructure Water Proofing

not relieve the Contractor/Subcontractor from the obligation responsibility under the contract and shall not constitute a departure from the contract


LEAD SECTOR CONSULTANT'S COMMENTS :

The system that is being proposed is not clear.

A proper submission, clearly indicating the system, test results, project reference to system etc.

EMPLOYER / PM COMMENTS :

should be submitted




27 JUN 2013

RECEIVED

SUBMITTAL STATUS	
APPROVED NO COMMENTS <input type="checkbox"/> APPROVED AS NOTED <input type="checkbox"/> NOT APPROVED - RESUBMIT <input checked="" type="checkbox"/>	FOR RECORD ONLY <input type="checkbox"/> EMPLOYER APPROVAL REQUIRED <input type="checkbox"/>

LEAD SECTOR CONSULTANT'S SIGNATURE

For and on behalf of
Arif & Bint oak


 Date: 27/6/2013



22 JUN 2013

RECEIVED

1485